### **STAMFORD**<sup>°</sup> Alternator Service Guide



### Introduction

Scheduled service and repair are vital to the reliable operation of your alternator and the safety of those who come in contact with it.

The service activities included in this guide are intended to maximise the life of the alternator, but will not vary, extend or change the terms of the manufacturer's standard warranty or your obligations in that warranty.

Each service interval should be used as a guide only, and developed on the basis that the alternator was installed and is operated in accordance with the manufacturer's guidelines. If the alternator is located and/or operated in adverse or unusual environmental conditions, the service intervals may need to be more frequent. The alternator should be continually monitored between service to identify any potential failure modes, signs of misuse, or excessive wear and tear.



### Disclaimer

This guide contains guidance and instructions for servicing and maintenance of the alternator only.

Before operating the alternator, refer to the Installation, Service and Maintenance manual to make sure that all personnel who work on the equipment have access to the manual and all additional documentation supplied with it. Misuse and failure to follow the instructions, and the use of non-approved parts, may invalidate the product warranty and lead to potential accidents.

The manual is an essential part of the alternator and should be available to all users throughout its life.

This guide states service intervals and key components to inspect throughout the life of the alternator. Refer to the full instructions in the Installation, Service & Maintenance manual when servicing the alternator.

This guide is written for skilled electrical and mechanical technicians and engineers, who have prior knowledge and experience of generating equipment of this type. If in doubt, please seek expert advice or contact your local Cummins Generator Technologies subsidiary.





Information in this guide was correct at time of going to print. It may be superseded due to our policy of continuous improvement.

Please visit:

www.stamford-avk.com for latest documentation.



### Safety Precautions



#### Safety Information and Notices

Danger, Warning and Caution panels are used in this manual to describe the sources of hazards, their consequences and how to avoid injury. Notice panels emphasize important or critical instructions.

#### DANGER

Danger indicates a hazardous situation which, if not avoided, WILL result in death or serious injury.

#### 🕂 WARNING

Warning indicates a hazardous situation which, if not avoided, COULD result in death or serious injury.

#### 

Caution indicates a hazardous situation which, if not avoided, COULD result in minor or moderate injury.

#### NOTICE

Caution indicates a hazardous situation which, if not avoided, COULD result in minor or moderate injury.



#### **General Guidance**

#### NOTICE

These safety precautions are for general guidance and supplement your own safety procedures and all applicable laws and standards.

#### **Skill Requirements of Personnel**

Service and maintenance procedures must only be carried out by experienced and qualified engineers, who are familiar with the procedures and the equipment.

#### **Risk Assessment**

A risk assessment has been performed on this product by Cummins, however a separate risk assessment must be performed by the user/operating company to establish all personnel-related risks. All affected users must be trained on the identified risks. Access to the Power PlanUGenerator Set during operation must be restricted to persons who have been trained on these risks.



#### **Personal Protective Equipment (PPE)**

All persons operating, servicing, maintaining or working in or with a power plant or a generator set must wear appropriate Personal Protective Equipment (PPE) Recommended PPE includes:

- Ear and Eye Protection
- Head and face protection
- Safety footwear
- Overalls that protect the lower arms and legs

Ensure that all persons are fully aware of the emergency procedures in case of accidents.

#### Noise

#### <u> W</u>ARNING

Noise from a running alternator can cause serious injury by permanent hearing damage. To prevent injury, wear appropriate personal protection equipment (PPE).

Maximum A-weighted noise emissions depend on alternator type. Contact the supplier for application-specific details.



#### **Electrical Equipment**

#### DANGER

Live electrical conductors can cause serious injury or death by electric shock and burns. To prevent injury and before removing covers over electrical conductors, isolate the generator set from all energy sources, remove stored energy and use lock out/tag out safety procedures.

All electrical equipment can be dangerous if not operated correctly. Always install, service and maintain the alternator in accordance with this manual. Work that requires access to electrical conductors must comply with all applicable local and national electrical safety procedures for the voltages involved and any site specific rules. Always use genuine branded replacement parts.

#### Lock Out/Tag Out

#### 🕂 WARNING

**Reconnected Energy Source** 

Accidental reconnection of energy sources during service and maintenance work can cause serious injury or death by electric shock, burns, crushing, severing or trapping.

To prevent injury and before starting service and maintenance work, use appropriate lock out/tag out safety procedures to keep the generator set isolated from energy sources. Do not defeat or bypass the lock out/tag out safety procedures.



#### Lifting

#### 🚹 DANGER

Falling mechanical parts can cause serious injury or death by impact, crushing, severing or trapping. To prevent injury and before lifting:

- Check the capacity, condition and attachment of lifting equipment (crane, hoists and jacks, including attachments to anchor, fix or support the equipment).
- Check the capacity, condition and attachment of accessories for lifting (hooks, slings, shackles and eye bolts for attaching loads to lifting equipment).
- Check the capacity, condition and attachment of lifting fixtures on the load.
- Check the mass, integrity and stability (e.g. unbalanced or shifting center of gravity) of the load.

#### 

Falling mechanical parts can cause serious injury or death by impact, crushing, severing or trapping.

To prevent injury and before lifting the alternator:

- Do not lift the complete generator set by the alternator lifting fixtures.
- · Keep the alternator horizontal when lifting.
- Fit drive end and non-drive end transit fittings to single bearing alternators to keep the main rotor in the frame.

Do not remove the lifting label attached to one of the lifting points.



#### **Alternator Operating Areas**


#### 🕂 WARNING

Debris ejected during catastrophic failure can cause serious injury or death by impact, severing or stabbing.

To prevent injury:

- Keep away from the air inlet and air outlet when the alternator is running.
- Do not put operator controls near the air inlet and air outlet.
- Do not cause overheating by running the alternator outside rating plate parameters.
- Do not overload the alternator.
- Do not run an alternator with excessive vibration.
- Do not synchronize parallel alternators outside the specified parameters.

Always wear suitable PPE when working in the hatched areas shown in the diagram or directly in-line with any air inlet/outlet. Make sure this consideration is captured in your risk assessment.





#### **Hazard Warning Labels**

#### <u> MARNING</u>

Safety Cover Removed

A hazard exposed when a safety cover is removed can cause serious injury or death.

To prevent injury:

- Fit the safety labels at the locations shown on the back of the label sheet supplied.
- · Observe the safety labels.
- · Refer to the service manual before removing covers.

The generator set manufacturer is responsible for fitting the self-adhesive hazard warning labels supplied with the alternator.

Replace labels that are missing, damaged or painted over.



#### Hazard Warning Labels - continued



## PO/P1

### **Alternator**

#### PO/P1 Alternator





## PO/P1 Alternator

#### Commission

Alternator	Controls and Auxiliaries	Windings	Bearings
nspect Alternator rating Bedplate arrangement Coupling arrangement Environmental conditions and cleanliness Complete machine damage, loose parts and earth bonds Guards, screens, warning and safety labels Maintenance access	Inspect Synchronisation settings Test Initial AVR set up AVR settings while alternator is running Customer connections of auxiliaries Function of auxiliaries Synchronisation while alternator is running	<ul> <li>Inspect</li> <li>Condition of windings</li> <li>Customer settings for temperature sensors</li> <li>Test</li> <li>Insulation resistance of all windings (P0/P1 test for LV)</li> <li>Insulation resistance of rotor, exciter and EBS</li> <li>Temperature sensors while alternator is running</li> </ul>	<ul> <li>Inspect</li> <li>Condition of bearings</li> <li>Customer settings for temperature sensors</li> <li>Test</li> <li>Temperature sensors while alternator is running</li> </ul>
<ul> <li>Ambient temperature (inside and outside)</li> </ul>	Cooling	Rectifier	Terminal Box
<ul> <li>and outside)</li> <li>Electrical nominal operating conditions and excitations while alternator is running</li> <li>Vibration while alternator is running</li> </ul>	<ul> <li>Inspect</li> <li>Air flow (rate and direction while alternator is running)</li> <li>Condition of fan</li> <li>Test</li> <li>Condition of air filter</li> </ul>	Inspect Diodes and varistors	Inspect All alternator/customer Connections and cabling

## PO/P1 Alternator

#### Post Commission 250 Hours/6 Months

Alternator	Controls and Auxiliaries	Windings	Bearings
Inspect	Test	Inspect	Inspect
<ul> <li>Environmental conditions and cleanliness</li> </ul>	<ul> <li>AVR settings while alternator is running</li> </ul>	Condition of windings	Condition of bearings
Complete machine damage,	<ul> <li>Function of auxiliaries</li> </ul>	Test	
loose parts, and earth bonds	<ul> <li>Synchronisation while alternator is running</li> </ul>	<ul> <li>Insulation resistance of all windings (P0/P1 test for LV)</li> </ul>	
<ul> <li>Guards, screens, warning and safety labels</li> </ul>		Insulation resistance of rotor, exciter and EBS	
Test		<ul> <li>Temperature sensors while alternator is running</li> </ul>	
<ul> <li>Ambient temperature (inside and outside)</li> </ul>			
<ul> <li>Electrical nominal operating conditions and excitations</li> </ul>			
while alternator is running	Cooling	Rectifier	Terminal Box
<ul> <li>Vibration while alternator is running</li> </ul>	Inspect	Inspect	Inspect
	Condition of fan	<ul> <li>Diodes and varistors</li> </ul>	<ul> <li>All alternator/customer connections and cabling</li> </ul>
	Test		
	Condition of air filter		
	Clean		
	Air filter		

#### 1,000 Hours/1 Year Service

PO/P1 Alternator

Alternator	Controls and Auxiliaries	Windings	Bearings
Inspect	Test	Inspect	Inspect
<ul> <li>Environmental conditions and cleanliness</li> </ul>	<ul> <li>AVR settings while alternator is running</li> </ul>	Condition of windings	Condition of bearings
<ul> <li>Complete machine damage, loose parts, and earth bonds</li> <li>Guards, screens, warning and safety labels</li> <li>Test</li> <li>Ambient temperature (inside and outside)</li> <li>Electrical nominal operating conditions and excitations</li> </ul>	<ul> <li>Customer connections of auxiliaries</li> <li>Function of auxiliaries</li> <li>Synchronisation while alternator is running</li> </ul>	<ul> <li>Test</li> <li>Insulation resistance of all windings (P0/P1 test for LV)</li> <li>Insulation resistance of rotor, exciter, and EBS</li> <li>Temperature sensors while alternator is running</li> </ul>	Test Temperature sensors while alternator is running
while alternator is running	Cooling	Rectifier	Terminal Box
<ul> <li>Vibration while alternator is running</li> </ul>	Inspect	Inspect	Inspect
Ū.	Condition of fan	<ul> <li>Diodes and varistors</li> </ul>	<ul> <li>All alternator/customer connections and cabling</li> </ul>
	Test		
	Condition of air filter		
	Clean		
	Air filter		

#### 10,000 Hours/2 Year Service

P0/P1 Alternator

Alternator	Controls and Auxiliaries	Windings	Bearings
Inspect	Inspect	Inspect	Inspect
<ul><li>Coupling arrangement</li><li>Environmental conditions and cleanliness</li></ul>	Anti condensation heater	Condition of windings	Condition of bearings
<ul> <li>Complete machine damage, loose parts, and earth bonds</li> </ul>	<ul> <li>AVR settings while alternator is running</li> </ul>	<ul> <li>Insulation resistance of all windings (P0/P1 test for LV)</li> </ul>	
<ul> <li>Guards, screens, warning and safety labels</li> </ul>	<ul><li>Customer connections of auxiliaries</li><li>Function of auxiliaries</li></ul>	<ul> <li>Temperature sensors while alternator is running</li> </ul>	
<ul><li>Test</li><li>Ambient temperature (inside and outside)</li></ul>	<ul> <li>Synchronisation while alternator is running</li> </ul>		
<ul> <li>Electrical nominal operating conditions and excitations while alternator is running</li> </ul>	Cooling	Rectifier	Terminal Box
<ul> <li>Vibration while alternator is running</li> </ul>	Inspect Condition of fan	Inspect Diodes and varistors	<ul> <li>Inspect</li> <li>All alternator/customer connections and cabling</li> </ul>
	Test Condition of air filter		
	Clean Air filter		

#### P0/P1 Alternator 30,000 Hours/5 Year Service Kits

For the 30,000 hour service interval we recommend replacing several components in order to optimise the alternator's performance.

For the P0/P1 alternator, the kits detailed in this table contain all parts necessary to execute the maintenance and repairs.

Kit Number	Contents
A051C107 (P0/P1 1 Bearing 30,000 Hour Service Kit)	<ul> <li>Rectifier Service Kit</li> <li>NDE Bearing Kit</li> </ul>
A051C115 P0/P1 2 Bearing 30,000 Hour Service Kit)	<ul> <li>Rectifier Service Kit</li> <li>DE and NDE Bearing Kit</li> </ul>

Frame	Part Number	Description
P0/P1	45-1161	Heater Kit UL 230V
P0/P1	45-1162	Heater Kit UL 115V
P0/P1	45-1163	Heater Kit UL 24V
P0/P1	45-1164	Heater Kit UL 12V

#### 30,000 Hours/5 Year Service

P0/P1 Alternator

Alternator	Controls and Auxiliaries	Windings	Bearings
Inspect         Coupling arrangement         Environmental conditions and cleanliness         Complete machine damage, loose parts, and earth bonds         Guards, screens, warning and safety labels         Test         Ambient temperature (inside	Replace         Anti condensation heater         Test         AVR settings while alternator is running         Customer connections of auxiliaries         Function of auxiliaries         Synchronisation while alternator is running	Inspect Condition of windings Test Insulation resistance of all windings (P0/P1 test for LV) Temperature sensors while alternator is running Insulation resistance of rotor, exciter and EBS	Replace Bearings
<ul> <li>and outside)</li> <li>Electrical nominal operating conditions and excitations while alternator is running</li> <li>Vibration while alternator is running</li> </ul>	Cooling Inspect Condition of fan Test Condition of Air filter	Rectifier Replace Diodes and varistors	Terminal Box Inspect All alternator/customer connections and cabling

## SO/S1 Alternator

#### SO/S1 Alternator





## S0/S1 Alternator

#### Commission

Alternator	Controls and Auxiliaries	Windings	Bearings
Inspect         Alternator rating         Bedplate arrangement         Coupling arrangement         Environmental conditions and cleanliness         Complete machine damage, loose parts and earth bonds         Guards, screens, warning and safety labels         Maintenance access	<ul> <li>Test</li> <li>Initial AVR set up</li> <li>AVR settings while alternator is running</li> <li>Customer connections of auxiliaries</li> <li>Function of auxiliaries</li> <li>Synchronisation while alternator is running</li> </ul>	<ul> <li>Inspect</li> <li>Condition of windings</li> <li>Test</li> <li>Insulation resistance of all windings (S0/S1 test for LV)</li> <li>Insulation resistance of rotor, exciter and auxiliary</li> </ul>	Inspect Condition of bearings
Test Ambient temperature (inside	Cooling	Rectifier	Terminal Box
<ul> <li>Ambient temperature (inside and outside)</li> <li>Electrical nominal operating conditions and excitations while alternator is running</li> <li>Vibration while alternator is running</li> </ul>	<ul> <li>Air flow (rate and direction while alternator is running)</li> <li>Condition of fan</li> </ul>	Diodes and varistors	All alternator/customer connections and cabling

## SO/S1 Alternator

#### Post Commission 250 Hours/6 Months

Alternator	Controls and Auxiliaries	Windings	Bearings
Inspect	Test	Inspect	Inspect
<ul> <li>Environmental conditions and cleanliness</li> </ul>	<ul> <li>AVR settings while alternator is running</li> </ul>	Condition of windings	Condition of bearings
Complete machine damage, loose parts, and earth bonds	Function of auxiliaries	Test ■ Insulation resistance of all windings (S0/S1 test for LV)	
<ul> <li>Guards, screens, warning and safety labels</li> </ul>		<ul> <li>Insulation resistance of rotor, exciter and auxiliary</li> </ul>	
Test			
<ul> <li>Ambient temperature (inside and outside)</li> </ul>			
<ul> <li>Electrical nominal operating conditions and excitations while alternator is running</li> </ul>	Cooling	Rectifier	Terminal Box
Vibration while alternator is	cooling	neeunei	Terminal Dox
running	Inspect	Inspect	Inspect
	Condition of fan	Diodes and varistors	<ul> <li>All alternator/customer connections and cabling</li> </ul>

#### 1,000 Hours/1 Year Service

ō	1,000 Hours/1 Year Service			
rna.	Alternator	Controls and Auxiliaries	Windings	Bearings
S0/S1 Alternator	Inspect         Environmental conditions and cleanliness         Complete machine damage, loose parts, and earth bonds         Guards, screens, warning and safety labels         Test         Ambient temperature (inside and outside)         Electrical nominal operating conditions and excitations	<ul> <li>Test</li> <li>AVR settings while alternator is running</li> <li>Customer connections of auxiliaries</li> <li>Function of auxiliaries</li> </ul>	<ul> <li>Inspect</li> <li>Condition of windings</li> <li>Test</li> <li>Insulation resistance of all windings (S0/S1 test for LV)</li> <li>Insulation resistance of rotor, exciter, and auxiliary</li> <li>Temperature sensors while alternator is running</li> </ul>	Inspect Condition of bearings
	<ul> <li>while alternator is running</li> <li>Vibration while alternator is running</li> </ul>	Cooling Inspect Condition of fan	Rectifier Inspect Diodes and varistors	Terminal Box Inspect All alternator/customer connections and cabling

#### 10,000 Hours/2 Year Service

Alternator	Controls and Auxiliaries	Windings	Bearings
<ul> <li>Inspect</li> <li>Coupling arrangement</li> <li>Environmental conditions and cleanliness</li> <li>Complete machine damage, loose parts, and earth bonds</li> <li>Guards, screens, warning and safety labels</li> </ul> Test	<ul> <li>Inspect</li> <li>Anti condensation heater</li> <li>Test</li> <li>AVR settings while alternator is running</li> <li>Customer connections of auxiliaries</li> <li>Function of auxiliaries</li> </ul>	Inspect Condition of windings Test Insulation resistance of all windings (S0/S1 test for LV)	Inspect Condition of bearings
<ul> <li>Ambient temperature (inside and outside)</li> <li>Electrical nominal operating conditions and excitations while alternator is running</li> <li>Vibration while alternator is running</li> </ul>	Cooling Inspect Condition of fan	Rectifier Inspect Diodes and varistors	Terminal Box Inspect All alternator/customer connections and cabling

S0/S1 Alternator

#### S0/S1 Alternator 30,000 Hours/5 Year Service Kits

For the 30,000 hour service interval we recommend replacing several components in order to optimise the alternator's performance.

For the S0/S1 alternator, the kits detailed in this table contain all parts necessary to execute the maintenance and repairs.

Kit Number	Contents
A051C107 (S1 Bearing 30,000 Hour Service Kit)	<ul><li>Rectifier Service Kit</li><li>NDE Bearing Kit</li></ul>
A054N489 (S0 Bearing 30,000 Hour Service Kit)	<ul> <li>Rectifier Service Kit</li> <li>NDE Bearing Kit</li> </ul>

Frame	Part Number	Description
S0/S1	A054K278	Heater Kit UL 12V
S0/S1	A054K280	Heater Kit UL 24V
S0/S1	A054K282	Heater Kit UL 115V
S0/S1	A054K284	Heater Kit UL 230V

#### 30,000 Hours/5 Year Service

S0/S1 Alternator

Alternator	Controls and Auxiliaries	Windings	Bearings
Inspect         Coupling arrangement         Environmental conditions and cleanliness         Complete machine damage, loose parts, and earth bonds         Guards, screens, warning and safety labels         Test         Ambient temperature (inside and outside)	<ul> <li>Replace</li> <li>Anti condensation heater</li> <li>Test</li> <li>AVR settings while alternator is running</li> <li>Customer connections of auxiliaries</li> <li>Function of auxiliaries</li> </ul>	Inspect Condition of windings Test Insulation resistance of all windings (S0/51 test for LV) Insulation resistance of rotor, exciter and auxiliary	Replace Bearings
<ul> <li>Electrical nominal operating conditions and excitations while alternator is running</li> <li>Vibration while alternator is running</li> </ul>	Cooling Inspect Condition of fan Test Condition of Air filter	Rectifier Replace Diodes and varistors	Terminal Box Inspect All alternator/customer connections and cabling

## UC22/UC27

### **Alternator**

#### UC22/UC27 Alternator





# UC22/UC27 Alternator

#### Commission

CONTINUESION			
Alternator	Controls and Auxiliaries	Windings	Bearings
Inspect Alternator rating Bedplate arrangement Coupling arrangement Finite Coupling arrangement Coupling arrangement Coupling arrangement Complete machine damage, loose parts and earth bonds Guards, screens, warning and safety labels Maintenance access Test	<ul> <li>Inspect</li> <li>Synchronisation settings</li> <li>Test</li> <li>Initial AVR set up</li> <li>AVR settings while alternator is running</li> <li>Customer connections of auxiliaries</li> <li>Function of auxiliaries</li> <li>Synchronisation while alternator is running</li> </ul>	<ul> <li>Inspect</li> <li>Condition of windings</li> <li>Customer settings for temperature sensors</li> <li>Test</li> <li>Insulation resistance of all windings (UC22/UC27 test for LV/MV)</li> <li>Temperature sensors while alternator is running</li> </ul>	<ul> <li>Inspect</li> <li>Condition of bearings</li> <li>Customer settings for temperature sensors</li> <li>Test</li> <li>Temperature sensors while alternator is running</li> </ul>
Ambient temperature (inside	Cooling	Rectifier	Terminal Box
<ul> <li>and outside)</li> <li>Electrical nominal operating conditions and excitations while alternator is running</li> <li>Vibration while alternator is running</li> </ul>	<ul> <li>Inspect</li> <li>Air flow (rate and direction while alternator is running)</li> <li>Condition of fan</li> <li>Test</li> <li>Condition of air filter</li> </ul>	<ul> <li>Inspect</li> <li>Diodes and varistors</li> <li>Three phase rectifier (if fitted)</li> </ul>	<ul> <li>Inspect</li> <li>All alternator/customer connections and cabling</li> </ul>

# UC22/UC27 Alternator

#### Post Commission 250 Hours/6 Months

Alternator	Controls and Auxiliaries	Windings	Bearings
Inspect	Test	Inspect	Inspect
<ul> <li>Environmental conditions and cleanliness</li> </ul>	<ul> <li>AVR settings while alternator is running</li> </ul>	Condition of windings	Condition of bearings
Complete machine damage,	<ul> <li>Function of auxiliaries</li> </ul>	Test	Test
loose parts, and earth bonds	<ul> <li>Synchronisation while alternator is running</li> </ul>	<ul> <li>Insulation resistance of all windings (UC22/UC27 test</li> </ul>	<ul> <li>Temperature sensors while alternator is running</li> </ul>
<ul> <li>Guards, screens, warning and safety labels</li> </ul>		for LV/MV)	alternator lo ranning
		<ul> <li>Insulation resistance of rotor, exciter and PMG</li> </ul>	
Test		Temperature sensors while	
<ul> <li>Ambient temperature (inside and outside)</li> </ul>		alternator is running	
<ul> <li>Electrical nominal operating conditions and excitations</li> </ul>		rotor, exciter and PMG	
while alternator is running	Cooling	Rectifier	Terminal Box
<ul> <li>Vibration while alternator is running</li> </ul>	Inspect	Inspect	Inspect
5	Condition of fan	Diodes and varistors	All alternator/customer
		Three phase rectifier	connections and cabling
	Test	(if fitted)	
	Condition of air filter		

#### 1,000 Hours/1 Year Service

UC22/UC27 Alternator

Alternator	Controls and Auxiliaries	Windings	Bearings
Inspect         Environmental conditions and cleanliness         Complete machine damage, loose parts, and earth bonds         Guards, screens, warning and safety labels         Test         Ambient temperature (inside and outside)         Electrical nominal operating	<ul> <li>Test</li> <li>AVR settings while alternator is running</li> <li>Customer connections of auxiliaries</li> <li>Function of auxiliaries</li> <li>Synchronisation while alternator is running</li> </ul>	<ul> <li>Inspect</li> <li>Condition of windings</li> <li>Test</li> <li>Insulation resistance of all windings (UC22/UC27 test for LV/MV)</li> <li>Insulation resistance of rotor, exciter, and PMG</li> <li>Temperature sensors while alternator is running</li> </ul>	Inspect Condition of bearings Test Test Temperature sensors while alternator is running
<ul> <li>conditions and excitations while alternator is running</li> <li>Vibration while alternator is running</li> </ul>	Cooling Inspect Condition of fan Test Condition of air filter Clean Air filter	Rectifier Inspect Diodes and varistors Three phase rectifier (if fitted)	Terminal Box Inspect All alternator/customer connections and cabling

#### 10,000 Hours/2 Year Service

Alternator	Controls and Auxiliaries	Windings	Bearings
Inspect Coupling arrangement Environmental conditions and cleanliness Complete machine damage, loose parts, and earth bonds Guards, screens, warning and safety labels Test Ambient temperature (inside and outside)	<ul> <li>Inspect</li> <li>Anti condensation heater</li> <li>Test</li> <li>AVR settings while alternator is running</li> <li>Customer connections of auxiliaries</li> <li>Function of auxiliaries</li> <li>Synchronisation while alternator is running</li> </ul>	<ul> <li>Inspect</li> <li>Condition of windings</li> <li>Test</li> <li>Insulation resistance of all windings (UC22/UC27 test for LV/MV)</li> <li>Temperature sensors while alternator is running</li> </ul>	Inspect Condition of bearings Test Temperature sensors while alternator is running
<ul> <li>Electrical nominal operating conditions and excitations while alternator is running</li> <li>Vibration while alternator is running</li> </ul>	Cooling Inspect Condition of fan Test Clean Air filter	Rectifier Inspect Diodes and varistors Three phase rectifier (if fitted)	Terminal Box Inspect All alternator/customer connections and cabling

#### UC22/UC27 Alternator 30,000 Hours/5 Year Service Kits

For the 30,000 hour service interval we recommend replacing several components in order to optimise the alternator's performance.

For the UC22/UC27 alternator, the kits detailed in this table contain all parts necessary to execute the maintenance and repairs.

Kit Number	Contents
A051C212 (UC22 1 Bearing 30,000 Hour Service Kit)	<ul><li>Rectifier Service Kit</li><li>NDE Bearing Kit</li></ul>
A051C216 (UC22 2 Bearing 30,000 Hour Service Kit)	<ul><li>Rectifier Service Kit</li><li>DE and NDE Bearing Kit</li></ul>
A051C218 (UC27 1 Bearing 30,000 Hour Service Kit)	<ul> <li>Rectifier Service Kit</li> <li>DE and NDE Bearing Kit</li> </ul>
A051C222 (UC27 2 Bearing 30,000 Hour Service Kit)	<ul> <li>Rectifier Service Kit</li> <li>DE and NDE Bearing Kit</li> </ul>

Frame	Part Number	Description
UC22/UC27	A053N107	Heater Kit UL 110-125V
UC22/UC27	A053N108	Heater Kit UL 220-260V

#### 30,000 Hours/5 Year Service

UC22/UC27 Alternator

Alternator	Controls and Auxiliaries	Windings	Bearings
<ul> <li>Inspect</li> <li>Coupling arrangement</li> <li>Environmental conditions and cleanliness</li> <li>Complete machine damage, loose parts, and earth bonds</li> <li>Guards, screens, warning and safety labels</li> <li>Test</li> <li>Ambient temperature (inside and outside)</li> </ul>	<ul> <li>Replace</li> <li>Anti condensation heater</li> <li>Test</li> <li>AVR settings while alternator is running</li> <li>Customer connections of auxiliaries</li> <li>Function of auxiliaries</li> <li>Synchronisation while alternator is running</li> </ul>	<ul> <li>Inspect</li> <li>Condition of windings</li> <li>Test</li> <li>Insulation resistance of all windings (UC22/UC27 test for LV/MV)</li> <li>Temperature sensors while alternator is running</li> <li>Insulation resistance of rotor, exciter and PMG</li> </ul>	<ul> <li>Replace</li> <li>Bearings</li> <li>Test</li> <li>Temperature sensors while alternator is running</li> </ul>
<ul> <li>Electrical nominal operating conditions and excitations while alternator is running</li> <li>Vibration while alternator is running</li> </ul>	Cooling Inspect Condition of fan Test Condition of air filter	Rectifier Replace Diodes and varistors	Terminal Box Inspect All alternator/customer connections and cabling

### HC4/HC5/HC6 Alternator

#### HC4/HC5/HC6 Alternator





# HC4/HC5/HC6 Alternator

#### Commission

Commission			
Alternator	Controls and Auxiliaries	Windings	Bearings
Inspect Alternator rating Bedplate arrangement Coupling arrangement Coupling arrangement Coupling arrangement Couplete machine damage, loose parts and earth bonds Guards, screens, warning and safety labels Maintenance access Test	Inspect Synchronisation settings Test Initial AVR and PFC set up AVR and PFC settings while alternator is running Customer connections of auxiliaries Function of auxiliaries Synchronisation while alternator is running	<ul> <li>Inspect</li> <li>Condition of windings</li> <li>Customer settings for temperature sensors</li> <li>Test</li> <li>Insulation resistance of all windings (HC4/HC5/HC6 test for LV/MV)</li> <li>Temperature sensors while alternator is running</li> </ul>	<ul> <li>Inspect</li> <li>Condition of bearings</li> <li>Customer settings for temperature sensors</li> <li>Test</li> <li>Temperature sensors while alternator is running</li> </ul>
<ul> <li>Ambient temperature (inside</li> </ul>	Cooling	Rectifier	Terminal Box
<ul> <li>and outside)</li> <li>Electrical nominal operating conditions and excitations while alternator is running</li> <li>Vibration while alternator is running</li> </ul>	<ul> <li>Inspect</li> <li>Air flow (rate and direction while alternator is running)</li> <li>Condition of fan</li> <li>Test</li> <li>Condition of air filter</li> </ul>	Inspect Diodes and varistors	Inspect All alternator/customer connections and cabling

# HC4/HC5/HC6 Alternator

#### Post Commission 250 Hours/6 Months

Alternator	Controls and Auxiliaries	Windings	Bearings
Inspect         Environmental conditions and cleanliness         Complete machine damage, loose parts, and earth bonds         Guards, screens, warning and safety labels         Test         Ambient temperature (inside and outside)         Electrical nominal operating	<ul> <li>Test</li> <li>AVR and PFC settings while alternator is running</li> <li>Function of auxiliaries</li> <li>Synchronisation while alternator is running</li> </ul>	Inspect Condition of windings Test Insulation resistance of all windings (HC4/HC5/HC6 test for LV/MV) Insulation resistance of rotor, exciter and PMG Temperature sensors while alternator is running Insulation resistance of rotor, exciter and PMG	Inspect Condition of bearings Test Temperature sensors while alternator is running Clean Grease exhaust and trap (Re-greasable bearings only) Replace Grease for re-greasable bearings
<ul> <li>conditions and excitations while alternator is running</li> <li>Vibration while alternator is running</li> </ul>	Cooling Inspect Condition of fan Test Condition of air filter Clean Air filter	Rectifier Inspect Diodes and varistors	Terminal Box Inspect All alternator/customer connections and cabling

#### 1,000 Hours/1 Year Service

HC4/HC5/HC6 Alternator

Alternator	Controls and Auxiliaries	Windings	Bearings
<ul> <li>Inspect</li> <li>Environmental conditions and cleanliness</li> <li>Complete machine damage, loose parts, and earth bonds</li> <li>Guards, screens, warning and safety labels</li> <li>Test</li> <li>Ambient temperature (inside and outside)</li> <li>Electrical nominal operating</li> </ul>	Test AVR and PFC settings while alternator is running Customer connections of auxiliaries Function of auxiliaries Synchronisation while alternator is running	<ul> <li>Inspect</li> <li>Condition of windings</li> <li>Test</li> <li>Insulation resistance of all windings (HC4/HC5/HC6 test for LV/MV)</li> <li>Insulation resistance of rotor, exciter, and PMG</li> <li>Temperature sensors while alternator is running</li> </ul>	Test Temperature sensors while alternator is running Replace Bearing greasee Clean Grease exhaust and trap
<ul> <li>conditions and excitations while alternator is running</li> <li>Vibration while alternator is running</li> </ul>	Cooling Inspect Condition of fan Test Clean Air filter	Rectifier Inspect Diodes and varistors	Terminal Box Inspect All alternator/customer connections and cabling

#### 10,000 Hours/2 Year Service

HC4/HC5/HC6 Alternator

Alternator	Controls and Auxiliaries	Windings	Bearings
<ul> <li>Inspect</li> <li>Coupling arrangement</li> <li>Environmental conditions and cleanliness</li> <li>Complete machine damage, loose parts, and earth bonds</li> <li>Guards, screens, warning and safety labels</li> <li>Test</li> <li>Ambient temperature (inside and outside)</li> </ul>	<ul> <li>Inspect</li> <li>Anti condensation heater</li> <li>Test</li> <li>AVR and PFC settings while alternator is running</li> <li>Customer connections of auxiliaries</li> <li>Function of auxiliaries</li> <li>Synchronisation while alternator is running</li> </ul>	<ul> <li>Inspect</li> <li>Condition of windings</li> <li>Test</li> <li>Insulation resistance of all windings (HC4/HC5/HC6 test for LV/MV)</li> <li>Temperature sensors while alternator is running</li> </ul>	Test Test Temperature sensors while alternator is running Replace Bearing grease Clean Grease exhaust and trap
<ul> <li>Electrical nominal operating conditions and excitations while alternator is running</li> <li>Vibration while alternator is running</li> </ul>	Cooling Inspect Condition of fan Test Clean Air filter	Rectifier Inspect Diodes and varistors	Terminal Box Inspect All alternator/customer connections and cabling

#### HC4/HC5/HC6 Alternator 30,000 Hours/5 Year Service Kits

For the 30,000 hour service interval we recommend replacing several components in order to optimise the alternator's performance.

For the HC4/HC5/HC6 alternator, the kits detailed in this table contain all parts necessary to execute the maintenance and repairs.

Frame	Part Number	Description
HC4	A053M965	Heater Kit UL 220-260V
HC4	A053M957	Heater Kit UL 110-125V
HC5/HC6	A053N002	Heater Kit UL 220-260V
HC5/HC6	A053M968	Heater Kit UI 110-125V

Kit Number	Contents
A051C225 (HC4 1 Bearing 30,000 Hour Service Kit)	<ul><li>Rectifier Service Kit</li><li>NDE Bearing Kit</li></ul>
A051C230 (HC4 2 Bearing 30,000 Hour Service Kit)	<ul><li>Rectifier Service Kit</li><li>DE and NDE Bearing Kit</li></ul>
A051C232 (HC5 1 SEALED Bearing 30,000 Hour Service Kit)	<ul><li>Rectifier Service Kit</li><li>NDE Bearing Kit</li></ul>
A051Z125 (HC5 1 RE-GREASABLE Bearing 30,000 Hour Service Kit)	<ul> <li>Rectifier Service Kit</li> <li>Re-grease NDE Bearing Kit</li> <li>Cartridge and Cap</li> </ul>
A051C234 (HC5 2 SEALED Bearing 30,000 Hour Service Kit)	<ul> <li>Rectifier Service Kit</li> <li>DE and NDE Bearing Kit</li> <li>Cartridge and Cap</li> </ul>
A051Z131 (HC5 2 RE-GREASABLE Bearing 30,000 Hour Service Kit)	<ul> <li>Rectifier Service Kit</li> <li>Regrease DE and NDE Bearing Kit</li> <li>Cartridge and Cap</li> </ul>
A051C237 (HC6 1 SEALED Bearing 30,000 Hour Service Kit)	<ul> <li>Rectifier Service Kit</li> <li>NDE Bearing Kit</li> <li>Cartridge and Cap</li> </ul>
A051Z133 (HC6 1 RE-GREASABLE Bearing 30,000 Hour Service Kit)	<ul> <li>Rectifier Service Kit</li> <li>Re-grease NDE Bearing Kit</li> <li>Cartridge and Cap</li> </ul>
A051C243 (HC6 2 SEALED Bearing 30,000 Hour Service Kit)	<ul> <li>Rectifier Service Kit</li> <li>DE and NDE Bearing Kit</li> <li>Cartridge and Cap</li> </ul>
A051Z137 (HC6 2 RE-GREASABLE Bearing 30,000 Hour Service Kit)	<ul> <li>Rectifier Service Kit</li> <li>Regrease DE and NDE Bearing Kit</li> <li>Cartridge and Cap</li> </ul>

#### 30,000 Hours/5 Year Service

Alternator	Controls and Auxiliaries	Windings	Bearings
<ul> <li>Inspect</li> <li>Coupling arrangement</li> <li>Environmental conditions and cleanliness</li> <li>Complete machine damage, loose parts, and earth bonds</li> <li>Guards, screens, warning and safety labels</li> </ul> Test <ul> <li>Ambient temperature (inside and outside)</li> </ul>	<ul> <li>Replace</li> <li>Anti condensation heater</li> <li>Test</li> <li>AVR and PFC settings while alternator is running</li> <li>Customer connections of auxiliaries</li> <li>Function of auxiliaries</li> <li>Synchronisation while alternator is running</li> </ul>	<ul> <li>Inspect</li> <li>Condition of Windings</li> <li>Test</li> <li>Insulation resistance of all windings (HC4/HC5/HC6 test for LV/MV)</li> <li>Temperature sensors while alternator is running</li> <li>Insulation resistance of rotor, exciter and PMG</li> </ul>	<ul> <li>Replace</li> <li>Bearings (sealed &amp; re-greasable</li> <li>Bearing grease</li> <li>Test</li> <li>Temperature sensors while alternator is running</li> <li>Clean</li> <li>Grease exhaust &amp; trap (re-greasable bearings only)</li> </ul>
<ul> <li>Electrical nominal operating conditions and excitations while alternator is running</li> <li>Vibration while alternator is running</li> </ul>	Cooling Inspect Condition of fan Test Clean Air filter	Rectifier Replace Diodes and varistors	Terminal Box Inspect All alternator/customer connections and cabling

### S4/S5/S6 Alternator

#### S4/S5/S6 Alternator





## S4/S5/S6 Alternator

#### Commission

0011111331011			
Alternator	Controls and Auxiliaries	Windings	Bearings
Inspect Alternator rating Alternator rating Bedplate arrangement Coupling arrangement Coupling arrangement Complete machine damage, loose parts and earth bonds Guards, screens, warning and safety labels Maintenance access Test	<ul> <li>Inspect</li> <li>Synchronisation settings</li> <li>Test</li> <li>Initial AVR and PFC set up</li> <li>AVR and PFC settings while alternator is running</li> <li>Customer connections of auxiliaries</li> <li>Function of auxiliaries</li> <li>Synchronisation while alternator is running</li> </ul>	<ul> <li>Inspect</li> <li>Condition of windings</li> <li>Customer settings for temperature sensors</li> <li>Test</li> <li>Insulation resistance of all windings</li> <li>Temperature sensors while alternator is running</li> </ul>	<ul> <li>Inspect</li> <li>Condition of bearings</li> <li>Customer settings for temperature sensors</li> <li>Test</li> <li>Temperature sensors while alternator is running</li> </ul>
<ul> <li>Ambient temperature (inside and outcide)</li> </ul>	Cooling	Rectifier	Terminal Box
<ul> <li>and outside)</li> <li>Electrical nominal operating conditions and excitations while alternator is running</li> <li>Vibration while alternator is running</li> </ul>	<ul> <li>Inspect</li> <li>Air flow (rate and direction while alternator is running)</li> <li>Condition of fan</li> <li>Test</li> <li>Condition of air filter</li> </ul>	Inspect Diodes and varistors	Inspect <ul> <li>All alternator/customer connections and cabling</li> </ul>

## S4/S5/S6 Alternator

#### Post Commission 250 Hours/6 Months

Alternator	Controls and Auxiliaries	Windings	Bearings
Inspect	Test	Inspect	Inspect
<ul> <li>Environmental conditions and cleanliness</li> </ul>	<ul> <li>AVR and PFC settings while alternator is running</li> </ul>	Condition of windings	Condition of bearings
<ul> <li>Complete machine damage, loose parts, and earth bonds</li> <li>Guards, screens, warning and safety labels</li> <li>Test</li> <li>Ambient temperature (inside and outside)</li> <li>Electrical nominal operating conditions and excitations</li> </ul>	<ul> <li>Function of auxiliaries</li> <li>Synchronisation while alternator is running</li> </ul>	Test Insulation resistance of all windings Insulation resistance of rotor, exciter and PMG Temperature sensors while alternator is running Insulation resistance of rotor, exciter and PMG	Test Temperature sensors while alternator is running Clean Grease exhaust and trap (Re-greasable bearings only) Replace Grease for re-greasable bearings
while alternator is running Vibration while alternator is	Cooling	Rectifier	Terminal Box
running	Inspect Condition of fan Test Clean Air filter	Inspect Diodes and varistors	Inspect All alternator/customer connections and cabling

#### 1,000 Hours/1 Year Service

Alternator	Controls and Auxiliaries	Windings	Bearings
Inspect         Environmental conditions and cleanliness         Complete machine damage, loose parts, and earth bonds         Guards, screens, warning and safety labels         Test         Ambient temperature (inside and outside)         Electrical nominal operating	<ul> <li>Test</li> <li>AVR and PFC settings while alternator is running</li> <li>Customer connections of auxiliaries</li> <li>Function of auxiliaries</li> <li>Synchronisation while alternator is running</li> </ul>	<ul> <li>Inspect</li> <li>Condition of windings</li> <li>Test</li> <li>Insulation resistance of all windings</li> <li>Insulation resistance of rotor, exciter, and PMG</li> <li>Temperature sensors while alternator is running</li> </ul>	Test Temperature sensors while alternator is running Replace Bearing grease Clean Grease exhaust and trap
<ul> <li>conditions and excitations while alternator is running</li> <li>Vibration while alternator is running</li> </ul>	Cooling Inspect Condition of fan Test Condition of air filter Clean Air filter	Rectifier Inspect Diodes and varistors	Terminal Box Inspect All alternator/customer connections and cabling

S4/S5/S6 Alternator

#### 10,000 Hours/2 Year Service

Alternator	Controls and Auxiliaries	Windings	Bearings
Inspect Coupling arrangement	Inspect Anti condensation heater	Inspect Condition of windings	Test Temperature sensors while alternator is running
<ul> <li>Environmental conditions and cleanliness</li> <li>Complete machine damage, loose parts, and earth bonds</li> <li>Guards, screens, warning and safety labels</li> <li>Test</li> <li>Ambient temperature (inside</li> </ul>	<ul> <li>Test</li> <li>AVR and PFC settings while alternator is running</li> <li>Customer connections of auxiliaries</li> <li>Function of auxiliaries</li> <li>Synchronisation while alternator is running</li> </ul>	<ul><li>Test</li><li>Insulation resistance of all windings</li><li>Temperature sensors while alternator is running</li></ul>	alternator is running Replace Bearing grease Clean Grease exhaust and trap
<ul> <li>Ambient temperature (inside and outside)</li> <li>Electrical nominal operating conditions and excitations while alternator is running</li> </ul>	Cooling	Rectifier	Terminal Box
<ul> <li>Vibration while alternator is running</li> </ul>	Inspect Condition of fan Condition of air filter Air filter	Inspect Diodes and varistors	Inspect All alternator/customer connections and cabling

S4/S5/S6 Alternator

#### S4/S5/S6 Alternator 30,000 Hours/5 Year Service Kits

For the 30,000 hour service interval we recommend replacing several components in order to optimise the alternator's performance.

For the S4/S5/S6 alternator, the kits detailed in this table contain all parts necessary to execute the maintenance and repairs.

Frame	Part Number	Description
S4	A053M965	Heater Kit UL 220-260V
S4	A053M957	Heater Kit UL 110-125V
S5/S6	A053N002	Heater Kit UL 220-260V
S5/S6	A053M968	Heater Kit UL 110-125V

Kit Number	Contents
A051C225 (HC4/S4 1 Bearing 30,000 Hour Service Kit)	<ul><li>Rectifier Service Kit</li><li>NDE Bearing Kit</li></ul>
A051C230 (HC4/S4 2 Bearing 30,000 Hour Service Kit)	<ul><li>Rectifier Service Kit</li><li>DE and NDE Bearing Kit</li></ul>
A051C232 (HC5/ S5/S5D 1 SEALED Bearing 30,000 Hour Service Kit)	<ul><li>Rectifier Service Kit</li><li>NDE Bearing Kit</li></ul>
A051Z125 (HC5 / S5 1 RE-GREASABLE Bearing 30,000 Hour Service Kit	<ul> <li>Rectifier Service Kit</li> <li>Regrease NDE Bearing Kit</li> <li>Cartridge and Cap</li> </ul>
A051C234 (HC5 / S5 2 SEALED Bearing 30,000 Hour Service Kit)	<ul> <li>Rectifier Service Kit</li> <li>Sealed DE and NDE Bearing Kit</li> <li>Cartridge and Cap</li> </ul>
A051Z131 (HC5 / S5 2 RE-GREASABLE Bearing 30,000 Hour Service Kit)	<ul> <li>Rectifier Service Kit</li> <li>Regrease DE and NDE Bearing Kit</li> <li>Cartridge and Cap</li> </ul>
A051C237 (HC6/S6/S6L1D G-H Core 1 SEALED Bearing 30,000 Hour Service Kit)	<ul> <li>Rectifier Service Kit</li> <li>Sealed DE and NDE Bearing Kit</li> <li>Cartridge and Cap</li> </ul>
A051C243 (HC6/S6/S6L1D G-H Core 2 SEALED Bearing 30,000 Hour Service Kit)	<ul> <li>Rectifier Service Kit</li> <li>Sealed DE and NDE Bearing Kit</li> <li>Cartridge and Cap</li> </ul>
A059R029 (S6L1D C-F Core 2 SEALED Bearing 30,000 Hour Service Kit)	<ul> <li>Rectifier Service Kit</li> <li>Sealed DE and NDE Bearing Kit</li> <li>Cartridge and Cap</li> </ul>
A051Z133 (HC6/S6 1 RE-GREASABLE Bearing 30,000 Hour Service Kit)	<ul> <li>Rectifier Service Kit</li> <li>Regrease NDE Bearing Kit</li> <li>Cartridge and Cap</li> </ul>
A051Z137 (HC6/S6 2 RE-GREASABLE Bearing 30,000 Hour Service Kit)	<ul> <li>Rectifier Service Kit</li> <li>Regrease DE and NDE Bearing Kit</li> <li>Cartridge and Cap</li> </ul>

#### 30,000 Hours/5 Year Service

Alternator	Controls and Auxiliaries	Windings	Bearings
<ul> <li>Inspect</li> <li>Coupling arrangement</li> <li>Environmental conditions and cleanliness</li> <li>Complete machine damage, loose parts, and earth bonds</li> <li>Guards, screens, warning and safety labels</li> <li>Test</li> <li>Ambient temperature (inside and outside)</li> </ul>	<ul> <li>Replace</li> <li>Anti condensation heater</li> <li>Test</li> <li>AVR and PFC settings while alternator is running</li> <li>Customer connections of auxiliaries</li> <li>Function of auxiliaries</li> <li>Synchronisation while alternator is running</li> </ul>	Inspect Condition of Windings Test Insulation resistance of all windings Temperature sensors while alternator is running Insulation resistance of rotor, exciter and PMG	Replace         Bearings (sealed & re-greasable         Bearing grease         Test         Temperature sensors while alternator is running         Clean         Grease exhaust & trap (re-greasable bearings only)
<ul> <li>Electrical nominal operating conditions and excitations while alternator is running</li> <li>Vibration while alternator is running</li> </ul>	Cooling Inspect Condition of fan Test Condition of air filter Clean Air filter	Rectifier Replace Diodes and varistors	Terminal Box Inspect All alternator/customer connections and cabling

S4/S5/S6 Alternator

### **Alternator**





### P7 Alternator

#### Commission

Alternator	Controls and Auxiliaries	Windings	Bearings
Inspect         Alternator rating         Bedplate arrangement         Coupling arrangement         Environmental conditions and cleanliness         Complete machine damage, loose parts and earth bonds         Guards, screens, warning and safety labels         Maintenance access	<ul> <li>Inspect</li> <li>Synchronisation settings</li> <li>Test</li> <li>Initial AVR and PFC set up</li> <li>AVR and PFC settings settings while alternator is running</li> <li>Customer connections of auxiliaries</li> <li>Function of auxiliaries</li> <li>Synchronisation while alternator is running</li> </ul>	<ul> <li>Inspect</li> <li>Condition of windings</li> <li>Customer settings for temperature sensors</li> <li>Test</li> <li>Insulation resistance of all windings (P7 test for LV/MV)</li> <li>Temperature sensors while alternator is running</li> </ul>	<ul> <li>Inspect</li> <li>Condition of bearings</li> <li>Customer settings for temperature sensors</li> <li>Test</li> <li>Temperature sensors while alternator is running</li> </ul>
<ul> <li>Ambient temperature (inside and outside)</li> </ul>	Cooling	Rectifier	Terminal Box
<ul> <li>Electrical nominal operating conditions and excitations while alternator is running</li> <li>Vibration while alternator is running</li> </ul>	<ul> <li>Inspect</li> <li>Air flow (rate and direction while alternator is running)</li> <li>Condition of fan</li> <li>Test</li> <li>Condition of air filter</li> </ul>	Inspect Diodes and varistors	Inspect All alternator/customer connections and cabling

### P7 Alternator

#### Post Commission 250 Hours/6 Months

Alternator	Controls and Auxiliaries	Windings	Bearings
Inspect	Test	Inspect	Inspect
<ul> <li>Environmental conditions and cleanliness</li> </ul>	<ul> <li>AVR and PFC settings while alternator is running</li> </ul>	Condition of windings	<ul> <li>Condition of bearings</li> </ul>
<ul> <li>Complete machine damage, loose parts, and earth bonds</li> <li>Guards, screens, warning and safety labels</li> <li>Test</li> <li>Ambient temperature (inside and outside)</li> <li>Electrical nominal operating conditions and excitations</li> </ul>	<ul> <li>Function of auxiliaries</li> <li>Synchronisation while alternator is running</li> </ul>	<ul> <li>Test</li> <li>Insulation resistance of all windings (P7 test for LV/MV)</li> <li>Insulation resistance of rotor, exciter and PMG</li> <li>Temperature sensors while alternator is running</li> </ul>	Test Temperature sensors while alternator is running Clean Grease exhaust and trap (Re-greasable bearings only) Replace Grease for re-greasable bearings
while alternator is running	Cooling	Rectifier	Terminal Box
Vibration while alternator is running	Inspect Condition of fan Test Clean Air filter	Inspect Diodes and varistors	Inspect <ul> <li>All alternator/customer connections and cabling</li> </ul>

#### 1,000 Hours/1 Year Service

Alternator	Controls and Auxiliaries	Windings	Bearings
<ul> <li>Inspect</li> <li>Environmental conditions and cleanliness</li> <li>Complete machine damage, loose parts, and earth bonds</li> <li>Guards, screens, warning and safety labels</li> <li>Test</li> <li>Ambient temperature (inside and outside)</li> <li>Electrical nominal operating</li> </ul>	<ul> <li>Test</li> <li>AVR and PFC settings while alternator is running</li> <li>Customer connections of auxiliaries</li> <li>Function of auxiliaries</li> <li>Synchronisation while alternator is running</li> </ul>	<ul> <li>Inspect</li> <li>Condition of windings</li> <li>Test</li> <li>Insulation resistance of all windings (P7 test for LV/MV)</li> <li>Insulation resistance of rotor, exciter, and PMG</li> <li>Temperature sensors while alternator is running</li> </ul>	Inspect Condition of bearings Test Temperature sensors while alternator is running Clean Grease exhaust and trap (Re-greasable bearings only) Replace Grease for re-greasable bearings
<ul> <li>conditions and excitations while alternator is running</li> <li>Vibration while alternator is running</li> </ul>	Cooling Inspect Condition of fan Test Condition of air filter Clean Air filter	Rectifier Inspect Diodes and varistors	Terminal Box Inspect All alternator/customer connections and cabling

P7 Alternator

#### 10,000 Hours/2 Year Service

Alternator	Controls and Auxiliaries	Windings	Bearings
<ul> <li>Inspect</li> <li>Coupling arrangement</li> <li>Environmental conditions and cleanliness</li> <li>Complete machine damage, loose parts, and earth bonds</li> <li>Guards, screens, warning and safety labels</li> </ul> Test <ul> <li>Ambient temperature (inside and outside)</li> </ul>	<ul> <li>Inspect</li> <li>Anti condensation heater</li> <li>Test</li> <li>AVR and PFC settings while alternator is running</li> <li>Customer connections of auxiliaries</li> <li>Function of auxiliaries</li> <li>Synchronisation while alternator is running</li> </ul>	<ul> <li>Inspect</li> <li>Condition of windings</li> <li>Test</li> <li>Insulation resistance of all windings (P7 test for LV/MV)</li> <li>Temperature sensors while alternator is running</li> </ul>	Inspect Condition of bearings Test Temperature sensors while alternator is running Clean Grease exhaust and trap (Re-greasable bearings only) Replace Grease for re-greasable bearings
<ul> <li>Electrical nominal operating conditions and excitations while alternator is running</li> <li>Vibration while alternator is running</li> </ul>	Cooling Inspect Condition of fan Test Clean Air filter	Rectifier Inspect Diodes and varistors	Terminal Box Inspect All alternator/customer connections and cabling

P7 Alternator

#### P7 Alternator 30,000 Hours/5 Year Service Kits

For the 30,000 hour service interval we recommend replacing several components in order to optimise the alternator's performance.

For the P7 alternator, the kits detailed in this table contain all parts necessary to execute the maintenance and repairs.

Kit Number	Contents
A051C251 (P7/S7 LV & S7 HV 1 RE-GREASABLE Bearing 30,000 Hour Service Kit)	<ul> <li>Rectifier Service Kit</li> <li>NDE Bearing Kit</li> <li>Cartridge and Cap</li> </ul>
A051Z145 (P7/S7 LV & S7 HV 1 SEALED Bearing 30,000 HourService Kit)	<ul><li>Rectifier Service Kit</li><li>NDE Bearing Kit</li><li>Cartridge and Cap</li></ul>
A051C255 (P7 A-E core/S7 LV C-F core 2 RE-GREASABLE Bearing 30,000 Hour Service Kit)	<ul><li>Rectifier Service Kit</li><li>DE Bearing Kit</li><li>Cartridge and Cap</li></ul>
A051C257 (P7 F-G core/S7 LV G-J core & S7 HV G-J core 2 RE-GREASABLE Bearing 30,000 Hour Service Kit)	<ul><li>Rectifier Service Kit</li><li>DE Bearing Kit</li><li>Cartridge and Cap</li></ul>

Frame	Part Number	Description
P7 A-F	A053N003	Heater Kit UL 220-260V
P7 A-F	A053M969	Heater Kit UL 110-125V
P7 G-H	A053N109	Heater Kit UL 220-260V
Р7 G-Н	A053M999	Heater Kit UL 110-125V

#### 30,000 Hours/5 Year Service

Alternator	Controls and Auxiliaries	Windings	Bearings
Inspect Coupling arrangement Environmental conditions and cleanliness Complete machine damage, loose parts, and earth bonds Guards, screens, warning and safety labels Test Ambient temperature (inside and outside)	<ul> <li>Replace</li> <li>Anti condensation heater</li> <li>Test</li> <li>AVR and PFC settings while alternator is running</li> <li>Customer connections of auxiliaries</li> <li>Function of auxiliaries</li> <li>Synchronisation while alternator is running</li> </ul>	Inspect Condition of windings Test Insulation resistance of all windings (P7 test for LV/MV) Temperature sensors while alternator is running Insulation resistance of rotor, exciter and PMG	Replace         Bearings (Sealed & re-greasable)         Bearing grease         Test         Temperature sensors while alternator is running         Clean         Grease exhaust & trap (re-greasable bearings only)
<ul> <li>Electrical nominal operating conditions and excitations while alternator is running</li> <li>Vibration while alternator is running</li> </ul>	Cooling Inspect Condition of fan Test Clean Air filter	Rectifier Replace Diodes and varistors	Terminal Box Inspect All alternator/customer connections and cabling

P7 Alternator

### Alternator

#### S7 Alternator





### S7 Alternator

#### Commission

Alternator	Controls and Auxiliaries	Windings	Bearings
Inspect Alternator rating Bedplate arrangement Coupling arrangement Environmental conditions and cleanliness Complete machine damage, loose parts and earth bonds Guards, screens, warning and safety labels Maintenance access	Inspect Synchronisation settings Test Initial AVR and PFC set up AVR and PFC settings settings while alternator is running Customer connections of auxiliaries Function of auxiliaries Synchronisation while	Inspect Condition of windings Customer settings for temperature sensors Test Insulation resistance of all windings (P7 test for LV/MV) Temperature sensors while alternator is running	Inspect Condition of bearings Customer settings for temperature sensors Test Temperature sensors while alternator is running
Test ■ Ambient temperature (inside and outside)	alternator is running Cooling	Rectifier	Terminal Box
<ul> <li>Electrical nominal operating conditions and excitations while alternator is running</li> <li>Vibration while alternator is running</li> </ul>	<ul> <li>Inspect</li> <li>Air flow (rate and direction while alternator is running)</li> <li>Condition of fan</li> <li>Test</li> <li>Condition of air filter</li> </ul>	Inspect Diodes and varistors	Inspect All alternator/customer connections and cabling

### S7 Alternator

#### Post Commission 250 Hours/6 Months

Alternator	Controls and Auxiliaries	Windings	Bearings
Inspect	Test	Inspect	Inspect
<ul> <li>Environmental conditions and cleanliness</li> </ul>	<ul> <li>AVR and PFC settings while alternator is running</li> </ul>	Condition of windings	Condition of bearings
<ul> <li>Complete machine damage, loose parts, and earth bonds</li> <li>Guards, screens, warning and safety labels</li> <li>Test</li> <li>Ambient temperature (inside and outside)</li> <li>Electrical nominal operating conditions and excitations</li> </ul>	<ul> <li>Function of auxiliaries</li> <li>Synchronisation while alternator is running</li> </ul>	<ul> <li>Test</li> <li>Insulation resistance of all windings (P7 test for LV/MV)</li> <li>Insulation resistance of rotor, exciter and PMG</li> <li>Temperature sensors while alternator is running</li> </ul>	Test Temperature sensors while alternator is running Clean Grease exhaust and trap (Re-greasable bearings only) Replace Grease for re-greasable bearings
while alternator is running	Cooling	Rectifier	Terminal Box
<ul> <li>Vibration while alternator is running</li> </ul>	Inspect Condition of fan Test Condition of air filter Clean Air filter	Inspect Diodes and varistors	Inspect All alternator/customer connections and cabling

#### 1,000 Hours/1 Year Service

Alternator	Controls and Auxiliaries	Windings	Bearings
Inspect         Environmental conditions and cleanliness         Complete machine damage, loose parts, and earth bonds         Guards, screens, warning and safety labels         Test         Ambient temperature (inside and outside)         Electrical nominal operating	<ul> <li>Test</li> <li>AVR and PFC settings while alternator is running</li> <li>Customer connections of auxiliaries</li> <li>Function of auxiliaries</li> <li>Synchronisation while alternator is running</li> </ul>	<ul> <li>Inspect</li> <li>Condition of windings</li> <li>Test</li> <li>Insulation resistance of all windings (P7 test for LV/MV)</li> <li>Insulation resistance of rotor, exciter, and PMG</li> <li>Temperature sensors while alternator is running</li> </ul>	Inspect Condition of bearings Test Test Temperature sensors while alternator is running Clean Grease exhaust and trap (Re-greasable bearings only) Replace Grease for re-greasable bearings
<ul> <li>conditions and excitations while alternator is running</li> <li>Vibration while alternator is running</li> </ul>	Cooling Inspect Condition of fan Test Clean Air filter	Rectifier Inspect Diodes and varistors	Terminal Box Inspect All alternator/customer connections and cabling

S7 Alternator

#### 10,000 Hours/2 Year Service

Alternator	Controls and Auxiliaries	Windings	Bearings
<ul> <li>Inspect</li> <li>Coupling arrangement</li> <li>Environmental conditions and cleanliness</li> <li>Complete machine damage, loose parts, and earth bonds</li> <li>Guards, screens, warning and safety labels</li> <li>Test</li> <li>Ambient temperature (inside and outside)</li> <li>Electrical nominal operating conditions and excitations while alternator is running</li> <li>Vibration while alternator is running</li> </ul>	<ul> <li>Inspect</li> <li>Anti condensation heater</li> <li>Test</li> <li>AVR and PFC settings while alternator is running</li> <li>Customer connections of auxiliaries</li> <li>Function of auxiliaries</li> <li>Synchronisation while alternator is running</li> </ul>	<ul> <li>Inspect</li> <li>Condition of windings</li> <li>Test</li> <li>Insulation resistance of all windings (P7 test for LV/MV)</li> <li>Temperature sensors while alternator is running</li> </ul>	Inspect Condition of bearings Test Temperature sensors while alternator is running Clean Grease exhaust and trap (Re-greasable bearings only) Replace Grease for re-greasable bearings
	Cooling Inspect Condition of fan Test Clean Air filter	Rectifier Inspect Diodes and varistors	Terminal Box Inspect All alternator/customer connections and cabling

S7 Alternator

#### S7 Alternator 30,000 Hours/5 Year Service Kits

For the 30,000 hour service interval we recommend replacing several components in order to optimise the alternator's performance.

For the S7 alternator, the kits detailed in this table contain all parts necessary to execute the maintenance and repairs.

Kit Number	Contents
A051C251 (P7/S7 LV & S7 HV 1 RE-GREASABLE Bearing 30,000 Hour Service Kit)	<ul><li>Rectifier Service Kit</li><li>NDE Bearing Kit</li><li>Cartridge and Cap</li></ul>
A051Z145 (P7/S7 LV & S7 HV 1 SEALED Bearing 30,000 HourService Kit)	<ul><li>Rectifier Service Kit</li><li>NDE Bearing Kit</li><li>Cartridge and Cap</li></ul>
A051C255 (P7 A-E core/S7 LV C-F core 2 RE-GREASABLE Bearing 30,000 Hour Service Kit)	<ul><li>Rectifier Service Kit</li><li>DE Bearing Kit</li><li>Cartridge and Cap</li></ul>
A051C257 (P7 F-G core/S7 LV G-J core & S7 HV G-J core 2 RE-GREASABLE Bearing 30,000 Hour Service Kit)	<ul><li>Rectifier Service Kit</li><li>DE Bearing Kit</li><li>Cartridge and Cap</li></ul>

Frame	Part Number	Description
S7 C-G	A053N003	Heater Kit UL 220-260V
S7 C-G	A053M969	Heater Kit UL 110-125V
S7 H-J	A053N109	Heater Kit UL 220-260V
S7 H-J	A053M999	Heater Kit UL 110-125V
S7 HV	A053M999 A064T028	Heater Kit UL 110V Heater Kit UL 240V

#### 30,000 Hours/5 Year Service

Alternator	Controls and Auxiliaries	Windings	Bearings
Inspect Coupling arrangement Environmental conditions and cleanliness Complete machine damage, loose parts, and earth bonds Guards, screens, warning and safety labels Test Ambient temperature (inside	<ul> <li>Replace</li> <li>Anti condensation heater</li> <li>Test</li> <li>AVR and PFC settings while alternator is running</li> <li>Customer connections of auxiliaries</li> <li>Function of auxiliaries</li> <li>Synchronisation while alternator is running</li> </ul>	Inspect Condition of windings Test Insulation resistance of all windings (S7 test for LV) Temperature sensors while alternator is running Insulation resistance of rotor, exciter and PMG	Replace         Bearings (Sealed & re-greasable)         Bearing grease         Test         Temperature sensors while alternator is running         Clean         Grease exhaust & trap (re-greasable bearings only)
<ul> <li>and outside)</li> <li>Electrical nominal operating conditions and excitations while alternator is running</li> <li>Vibration while alternator is running</li> </ul>	Cooling Inspect Condition of fan Test Clean Air filter	Rectifier Replace Diodes and varistors	<ul> <li>Terminal Box</li> <li>Inspect</li> <li>All alternator/customer connections and cabling</li> </ul>

S7 Alternator

### P80 Alternator



 Commission
 Post Commission
 1,000 Hour
 10,000 Hours
 30,000 Hours

 6 Month Service
 1 Year Service
 2 Year Service
 5 Year Service

### P80 Alternator

#### Commission

Alternator	Controls and Auxiliaries	Windings	Bearings
<ul> <li>Inspect</li> <li>Alternator rating</li> <li>Bedplate arrangement</li> <li>Coupling arrangement</li> <li>Environmental conditions and cleanliness</li> <li>Complete machine damage, loose parts and earth bonds</li> <li>Guards, screens, warning and safety labels</li> <li>Maintenance access</li> </ul>	<ul> <li>Inspect</li> <li>Synchronisation settings</li> <li>Test</li> <li>Initial AVR and PFC set up</li> <li>AVR and PFC settings settings while alternator is running</li> <li>Customer connections of auxiliaries</li> <li>Function of auxiliaries</li> <li>Synchronisation while alternator is running</li> </ul>	Inspect         Condition of windings         Customer settings for temperature sensors         Test         Insulation resistance of all windings (P80 test for MV/HV)         Temperature sensors while alternator is running	<ul> <li>Inspect</li> <li>Condition of bearings</li> <li>Customer settings for temperature sensors</li> <li>Test</li> <li>Temperature sensors while alternator is running</li> </ul>
<ul> <li>Ambient temperature (inside and outside)</li> <li>Electrical nominal operating conditions and excitations while alternator is running</li> <li>Vibration while alternator is running</li> </ul>	Cooling Inspect Air flow (rate and direction while alternator is running) Condition of fan Test Condition of air filter	Rectifier Inspect Diodes and surge suppressors	Terminal Box Inspect ■ All alternator/customer connections and cabling

# P80 Alternator

#### Post Commission 250 Hours/6 Months

Alternator	Controls and Auxiliaries	Windings	Bearings
Inspect	Test	Inspect	Inspect
<ul> <li>Environmental conditions and cleanliness</li> </ul>	<ul> <li>AVR and PFC settings while alternator is running</li> </ul>	Condition of windings	Condition of bearings
<ul> <li>Complete machine damage, loose parts, and earth bonds</li> <li>Guards, screens, warning and safety labels</li> <li>Test</li> <li>Ambient temperature (inside and outside)</li> <li>Electrical nominal operating conditions and excitations</li> </ul>	<ul> <li>Function of auxiliaries</li> <li>Synchronisation while alternator is running</li> </ul>	<ul> <li>Test</li> <li>Insulation resistance of all windings (P80 test for MV/HV)</li> <li>Insulation resistance of rotor, exciter and PMG</li> <li>Temperature sensors while alternator is running</li> </ul>	Test Tenperature sensors while alternator is running Clean Grease exhaust and trap (Re-greasable bearings only) Replace Grease for re-greasable bearings
while alternator is running	Cooling	Rectifier	Terminal Box
<ul> <li>Vibration while alternator is running</li> </ul>	Inspect Condition of fan Test Condition of air filter Clean Air filter	Inspect Diodes and surge suppressors	Inspect <ul> <li>All alternator/customer connections and cabling</li> </ul>

#### 1,000 Hours/1 Year Service

Alternator	Controls and Auxiliaries	Windings	Bearings
<ul> <li>Inspect</li> <li>Environmental conditions and cleanliness</li> <li>Complete machine damage, loose parts, and earth bonds</li> </ul>	Test AVR and PFC settings while alternator is running Customer connections of auxiliaries	Inspect Condition of windings Test Insulation resistance of	Inspect Condition of bearings Test Temperature sensors while alternator is running
<ul> <li>Guards, screens, warning and safety labels</li> <li>Test</li> <li>Ambient temperature (inside and outside)</li> <li>Electrical nominal operating conditions and excitations</li> </ul>	<ul> <li>Function of auxiliaries</li> <li>Synchronisation while alternator is running</li> </ul>	all windings (P80 test for MV/HV) Insulation resistance of rotor, exciter, and PMG Temperature sensors while alternator is running	Clean Grease exhaust and trap (Re-greasable bearings only) Replace Grease for re-greasable bearings
<ul> <li>vibrations and excitations while alternator is running</li> <li>Vibration while alternator is running</li> </ul>	Cooling Inspect Condition of fan Test Clean Air filter	Rectifier Inspect Diodes and surge suppressors	Terminal Box Inspect All alternator/customer connections and cabling

P80 Alternator

#### 10,000 Hours/2 Year Service

Alternator	Controls and Auxiliaries	Windings	Bearings
<ul> <li>Inspect</li> <li>Coupling arrangement</li> <li>Environmental conditions and cleanliness</li> <li>Complete machine damage, loose parts, and earth bonds</li> <li>Guards, screens, warning and safety labels</li> </ul> Test <ul> <li>Ambient temperature (inside and outside)</li> </ul>	<ul> <li>Inspect</li> <li>Anti condensation heater</li> <li>Test</li> <li>AVR and PFC settings while alternator is running</li> <li>Customer connections of auxiliaries</li> <li>Function of auxiliaries</li> <li>Synchronisation while alternator is running</li> </ul>	<ul> <li>Inspect</li> <li>Condition of windings</li> <li>Test</li> <li>Insulation resistance of all windings (P80 test for MV/HV)</li> <li>Temperature sensors while alternator is running</li> </ul>	Inspect Condition of bearings Test Temperature sensors while alternator is running Clean Grease exhaust and trap (Re-greasable bearings only) Replace Grease for re-greasable bearings
<ul> <li>Electrical nominal operating conditions and excitations while alternator is running</li> <li>Vibration while alternator is running</li> </ul>	Cooling Inspect Condition of fan Test Clean Air filter	Rectifier Inspect Diodes and surge suppressors	Terminal Box Inspect All alternator/customer connections and cabling

P80 Alternator

#### P80 Alternator 30,000 Hours/5 Year Service Kits

For the 30,000 hour service interval we recommend replacing several components in order to optimise the alternator's performance.

For the P80 alternator, the kits detailed in this table contain all parts necessary to execute the maintenance and repairs.

Kit Number	Contents
A051C282 (P80 1 Bearing 30,000 Hour Service Kit)	<ul><li>Rectifier Service Kit</li><li>NDE Bearing Kit</li></ul>
A051C285 (P80 2 Bearing 30,000 Hour Service Kit)	<ul><li>Rectifier Service Kit</li><li>Bearing Kit Frame R, S, &amp; T</li></ul>
A051C291 (P80 2 Bearing 30,000 Hour Service Kit)	<ul> <li>Rectifier Service Kit</li> <li>Bearing Kit Frame X, Y, &amp; Z</li> </ul>

Frame	Part Number	Description
P80	45-1029	Heater Kit UL

#### 30,000 Hours/5 Year Service

tor	30,000 Hours/5 Year Service			
rna	Alternator	Controls and Auxiliaries	Windings	Bearings
P80 Alternator	<ul> <li>Inspect</li> <li>Coupling arrangement</li> <li>Environmental conditions and cleanliness</li> <li>Complete machine damage, loose parts, and earth bonds</li> <li>Guards, screens, warning and safety labels</li> </ul> Test <ul> <li>Ambient temperature (inside and outside)</li> </ul>	<ul> <li>Replace</li> <li>Anti condensation heater</li> <li>Test</li> <li>AVR and PFC settings while alternator is running</li> <li>Customer connections of auxiliaries</li> <li>Function of auxiliaries</li> <li>Synchronisation while alternator is running</li> </ul>	<ul> <li>Inspect</li> <li>Condition of windings</li> <li>Test</li> <li>Insulation resistance of all windings (P80 test for MV/HV)</li> <li>Temperature sensors while alternator is running</li> <li>Insulation resistance of rotor, exciter and PMG</li> </ul>	<ul> <li>Replace</li> <li>Bearings (sealed &amp; re-greasable)</li> <li>Bearing grease</li> <li>Test</li> <li>Temperature sensors while alternator is running</li> <li>Clean</li> <li>Grease exhaust &amp; trap (re-greasable bearings only)</li> </ul>
	<ul> <li>Electrical nominal operating conditions and excitations while alternator is running</li> <li>Vibration while alternator is running</li> </ul>	Cooling Inspect Condition of fan Test Condition of air filter	Rectifier Replace Diodes and surge suppressors	Terminal Box Inspect All alternator/customer connections and cabling

### Alternator

59





## **S9 Alternator**

#### Commission

Alternator	Controls and Auxiliaries	Windings	Bearings
Inspect Alternator rating Alternator rating Eddplate arrangement Coupling arrangement Coupling arrangement Coupling arrangement Complete machine damage, loose parts and earth bonds Guards, screens, warning and safety labels Maintenance access Test	Inspect Synchronisation settings Test Initial AVR and PFC set up AVR and PFC settings settings while alternator is running Customer connections of auxiliaries Function of auxiliaries Synchronisation while alternator is running	<ul> <li>Inspect</li> <li>Condition of windings</li> <li>Customer settings for temperature sensors</li> <li>Test</li> <li>Insulation resistance of all windings (P80 test for MV/HV)</li> <li>Temperature sensors while alternator is running</li> </ul>	<ul> <li>Inspect</li> <li>Condition of bearings</li> <li>Customer settings for temperature sensors</li> <li>Test</li> <li>Temperature sensors while alternator is running</li> </ul>
<ul> <li>Ambient temperature (inside and outside)</li> </ul>	Cooling	Rectifier	Terminal Box
<ul> <li>Electrical nominal operating conditions and excitations while alternator is running</li> <li>Vibration while alternator is running</li> </ul>	Inspect         Air flow (rate and direction while alternator is running)         Condition of fan         Test         Condition of air filter	Inspect Diodes and surge suppressors	Inspect All alternator/customer connections and cabling

## **S9 Alternator**

#### Post Commission 250 Hours/6 Months

Alternator	Controls and Auxiliaries	Windings	Bearings
Inspect	Test	Inspect	Inspect
<ul> <li>Environmental conditions and cleanliness</li> </ul>	<ul> <li>AVR and PFC settings while alternator is running</li> </ul>	Condition of windings	Condition of bearings
<ul> <li>Complete machine damage, loose parts, and earth bonds</li> <li>Guards, screens, warning and safety labels</li> <li>Test</li> <li>Ambient temperature (inside and outside)</li> <li>Electrical nominal operating conditions and excitations</li> </ul>	<ul> <li>Function of auxiliaries</li> <li>Synchronisation while alternator is running</li> </ul>	<ul> <li>Test</li> <li>Insulation resistance of all windings (P80 test for MV/HV)</li> <li>Insulation resistance of rotor, exciter and PMG</li> <li>Temperature sensors while alternator is running</li> </ul>	Test Test Temperature sensors while alternator is running Clean Grease exhaust and trap (Re-greasable bearings only) Replace Grease for re-greasable bearings
while alternator is running	Cooling	Rectifier	Terminal Box
Vibration while alternator is running	Inspect Condition of fan Test Condition of air filter Clean Air filter	<ul> <li>Diodes and surge suppressors</li> </ul>	<ul> <li>Inspect</li> <li>All alternator/customer connections and cabling</li> </ul>

#### 1,000 Hours/1 Year Service

Alternator	Controls and Auxiliaries	Windings	Bearings
Inspect Environmental conditions and cleanliness Complete machine damage, loose parts, and earth	Test AVR and PFC settings while alternator is running Customer connections of auxiliaries	Inspect Condition of windings Test	Inspect Condition of bearings Test Temperature sensors while
<ul> <li>bonds</li> <li>Guards, screens, warning and safety labels</li> <li>Test</li> <li>Ambient temperature (inside and outside)</li> <li>Electrical nominal operating</li> </ul>	<ul><li>Function of auxiliaries</li><li>Synchronisation while alternator is running</li></ul>	<ul> <li>Insulation resistance of all windings (P80 test for MV/HV)</li> <li>Insulation resistance of rotor, exciter, and PMG</li> <li>Temperature sensors while alternator is running</li> </ul>	<ul> <li>I enjoyenature sensors while alternator is running</li> <li>Clean</li> <li>Grease exhaust and trap (Re-greasable bearings only)</li> <li>Replace</li> <li>Grease for re-greasable bearings</li> </ul>
<ul> <li>conditions and excitations while alternator is running</li> <li>Vibration while alternator is running</li> </ul>	Cooling Inspect Condition of fan Test Clean Air filter	Rectifier Inspect Diodes and surge suppressors	Terminal Box Inspect All alternator/customer connections and cabling

**S9 Alternator** 

#### 10,000 Hours/2 Year Service

Alternator	Controls and Auxiliaries	Windings	Bearings
<ul> <li>Inspect</li> <li>Coupling arrangement</li> <li>Environmental conditions and cleanliness</li> <li>Complete machine damage, loose parts, and earth bonds</li> <li>Guards, screens, warning and safety labels</li> </ul> Test <ul> <li>Ambient temperature (inside and outside)</li> </ul>	<ul> <li>Inspect</li> <li>Anti condensation heater</li> <li>Test</li> <li>AVR and PFC settings while alternator is running</li> <li>Customer connections of auxiliaries</li> <li>Function of auxiliaries</li> <li>Synchronisation while alternator is running</li> </ul>	<ul> <li>Inspect</li> <li>Condition of windings</li> <li>Test</li> <li>Insulation resistance of all windings (P80 test for MV/HV)</li> <li>Temperature sensors while alternator is running</li> </ul>	Inspect Condition of bearings Test Temperature sensors while alternator is running Clean Grease exhaust and trap (Re-greasable bearings only) Replace Grease for re-greasable bearings
<ul> <li>Electrical nominal operating conditions and excitations while alternator is running</li> <li>Vibration while alternator is running</li> </ul>	Cooling Inspect Condition of fan Test Clean Air filter	Rectifier Inspect Diodes and surge suppressors	Terminal Box Inspect All alternator/customer connections and cabling

**S9 Alternator** 

#### S9 Alternator 30,000 Hours/5 Year Service Kits

For the 30,000 hour service interval we recommend replacing several components in order to optimise the alternator's performance.

For the S9 alternator, the kits detailed in this table contain all parts necessary to execute the maintenance and repairs.

Kit Number	Contents
<b>A065P433</b> (S9 1 Bearing 30,000 Hour Service Kit)	<ul> <li>Rectifier Service Kit</li> <li>NDE Bearing Kit</li> </ul>
A065P434 (S9 2 Bearing 30,000 Hour Service Kit)	<ul> <li>Rectifier Service Kit</li> <li>Bearing Kit Frame B - D</li> </ul>
A065P435 (S9 2 Bearing 30,000 Hour Service Kit)	<ul> <li>Rectifier Service Kit</li> <li>Bearing Kit Frame E - F</li> </ul>
A065P436 (S9 2 Bearing 30,000 Hour Service Kit)	<ul><li>Rectifier Service Kit</li><li>Bearing Kit Frame G - H</li></ul>

Frame	Part Number	Description
S9	A059S757	F9 Heater Kit

#### 30,000 Hours/5 Year Service

Alternator	Controls and Auxiliaries	Windings	Bearings
<ul> <li>Inspect</li> <li>Coupling arrangement</li> <li>Environmental conditions and cleanliness</li> <li>Complete machine damage, loose parts, and earth bonds</li> <li>Guards, screens, warning and safety labels</li> </ul> Test <ul> <li>Ambient temperature (inside and outside)</li> <li>Electrical nominal operating conditions and excitations while alternator is running</li> <li>Vibration while alternator is running</li> </ul>	<ul> <li>Replace</li> <li>Anti condensation heater</li> <li>Test</li> <li>AVR and PFC settings while alternator is running</li> <li>Customer connections of auxiliaries</li> <li>Function of auxiliaries</li> <li>Synchronisation while alternator is running</li> </ul>	<ul> <li>Inspect</li> <li>Condition of windings</li> <li>Test</li> <li>Insulation resistance of all windings (P80 test for MV/HV)</li> <li>Temperature sensors while alternator is running</li> <li>Insulation resistance of rotor, exciter and PMG</li> </ul>	<ul> <li>Replace</li> <li>Bearings (sealed &amp; re-greasable)</li> <li>Bearing grease</li> <li>Test</li> <li>Temperature sensors while alternator is running</li> <li>Clean</li> <li>Grease exhaust &amp; trap (re-greasable bearings only)</li> </ul>
	Cooling Inspect Condition of fan Test Condition of air filter	Rectifier Replace Diodes and surge suppressors	Terminal Box Inspect All alternator/customer connections and cabling

**S9 Alternator** 

### Guaranteed **STAMFORD**®

We guarantee that every product we produce matches the quality, robustness, and proven performance you expect from the STAMFORD range. Built to our quality assured standards, STAMFORD products benefit from a global support network, extensive research and development, and worldleading expertise.

Where people need power, businesses rely on genuine STAMFORD alternators. Proven expertise in design, development, manufacturing, customer support and servicing, ensures quality in every aspect of our business.

Visit **stamford-avk.com/verify** to find out how we are protecting our customers and their businesses against the dangers of illegal, counterfeit and imitation products and taking action.



### The Power of More™

Selecting the right alternator for the right application in today's complex world is our goal - making your life simpler. We understand the performance requirements that each application and operating environment demands. Our knowledgeable and experienced Customer Engineers align individual customers' power needs with the most suitable alternator specification.

We take pride in our global reputation for Technical Support and After Sales Service, continually adding new, trained engineers in locations near to our customers, worldwide.

Cummins engineers are experienced professionals trained in electrical, electronic and mechanical engineering and are ready to help at any point in the **STAMFORD** alternator lifecycle, minimising risk of unexpected downtime. What this means to you:

- 24 hour response to service emergencies, 7 days a week
- Trained engineers available locally, speaking the local language
- Commissioning of alternators onsite
- Onsite bearing maintenance and bearing condition monitoring
- Onsite insulation integrity checks
- AVR and accessories set up onsite
- Extensive aftermarket distribution for genuine STAMFORD parts

#### For Customer Service:

Americas:

cgta.service@cummins.com Phone: +1-800-367-2764

EMEA:

emea.service@cummins.com Phone: +441780484732

APAC:

apac.service@cummins.com Phone: +8651081103212

China:

cgt.china.service@cummins.com Phone: +86 400 88 12390

India:

CGtil.csnotify@cummins.com Phone: +91 (0) 20 67067639

For general enquires: newagestamfordavk@cummins.com

www.stamford-avk.com



#### NEWAGE<sup>®</sup> | STAMFORD<sup>®</sup> | AvK<sup>®</sup>

Powering the world with confidence since 1904



Copyright 2020, Cummins Generator Technologies Ltd. All rights reserved. Cummins and the Cummins logo are registered trade marks of Cummins Inc. NEWAGE®, STAMFORD® and Ark® are registered trade marks of Cummins Generator Technologies Ltd.

Part No. PG\_SSG\_P\_EN\_AF Rev.06