



CORE	C OF G	WEIGHT (KG)
A (4p)	640	2710
B (4p)	640	2710
C (4p)	680	2967
B (6p)	640	2630

NOTE:-
 CUSTOMER MAY CUT CABLE ENTRY HOLES AS REQUIRED IN ANY OF THE FOUR TERMINAL BOX SIDES SUBJECT TO POSITION OF AVR, TERMINALS, ETC.
 NOTE:-
 VENTILATION SLOTS NOT REQUIRED ON SOME REDUCED LOAD APPLICATIONS

NO.	MOD.	ISSUE	DATE	ALTERATION	CERTIFIED PRINT	SCALE	FIRST W.O.
4-9514-02	D	MC	09/04/08	CHANGE OF DRAWING TITLE TO 'P17'. WAS 'P7'.	ONLY IF SIGNED	1:10	
4-8664-02	C	USD	14/09/06	CHANGE OF COMPANY NAME	BY		
4-7752-04	B	GTK	21/APR/2006	VENTILATION SLOTS: DEPICTION AND NOTE ADDED	DATE		
4/7752/01	A	DFC	14/03/05	ORIGINAL ISSUE	DRAWN		
					CHECKED		
					APPROVED		

Pl 7 A/B/C (4p) & B (6p) 2-BRG ALTERNATOR
 STANDARD TERMINAL BOX
 STANDARD FEET
 CUMMINS GENERATOR
 TECHNOLOGIES LTD.

CUSTOMER MUST ENSURE THAT AIR INLET & OUTLET POSITIONS ARE NOT OBSTRUCTED