
PM042E - Winding 311 Single Phase

Technical Data Sheet



PM042E SPECIFICATIONS & OPTIONS

STANDARDS

Marine generators may be certified to Lloyds, DnV, Bureau Veritas, ABS, Germanischer-Lloyd or RINA.

Other standards and certifications can be considered on request.

VOLTAGE REGULATOR

AS480 AVR

With this self-excited system the main stator provides power via the AVR to the exciter stator. The high efficiency semi-conductors of the AVR ensure positive build-up from initial low levels of residual voltage.

The exciter rotor output is fed to the main rotor through a three-phase full-wave bridge rectifier. The rectifier is protected by a surge suppressor against surges caused, for example, by short circuit or out-of-phase paralleling. The AS480 will support limited accessories, RFI suppession remote voltage trimmer and for the P1 range only a 'droop' Current Transformer (CT) to permit parallel operation with other ac generators.

The AVR is can be fitted to either side of the generator in its own housing in the non-drive end bracket.

Excitation Boost System (EBS)

The EBS is a single, self-contained unit, attached to the non-drive end of the generator.

The EBS unit consists of the Excitation Boost Controller (EBC) and an Excitation Boost Generator (EBG). Under fault conditions, or when the generator is subjected to a large impact load such as a motor starting, the generator voltage will drop. The EBC senses the drop in voltage and engages the output power of the EBG. This additional power feeds the generator's excitation system, supporting the load until breaker discrimination can remove the fault or enable the generator to pick up a motor and drive the voltage recovery.

WINDINGS & ELECTRICAL PERFORMANCE

All generator stators are wound to 2/3 pitch. This eliminates triplen (3rd, 9th, 15th ...) harmonics on the voltage waveform and is found to be the optimum design for trouble-free supply of non-linear loads. The 2/3 pitch design avoids excessive neutral currents sometimes seen with higher winding pitches, when in parallel with the mains. A fully connected damper winding reduces oscillations during paralleling. This winding, with the 2/3 pitch and carefully selected pole and tooth designs, ensures very low waveform distortion.

TERMINALS & TERMINAL BOX

Standard generators are reconnectable with 12 ends brought out to the terminals, which are mounted at the non drive end of the generator. Dedicated single phase generators are also available. A sheet steel terminal box contains provides ample space for the customers' wiring and gland arrangements. Alternative terminal boxes are available for customers who want to fit additional components in the terminal box.

SHAFT & KEYS

All generator rotors are dynamically balanced to better than BS6861:Part 1 Grade 2.5 for minimum vibration in operation. Two bearing generators are balanced with a half key.

INSULATION / IMPREGNATION

The insulation system is class 'H'.

All wound components are impregnated with materials and processes designed specifically to provide the high build required for static windings and the high mechanical strength required for rotating components.

QUALITY ASSURANCE

Generators are manufactured using production procedures having a quality assurance level to BS EN ISO 9001.

The stated voltage regulation may not be maintained in the presence of certain radio transmitted signals. Any change in performance will fall within the limits of Criteria b' of EN 61000-6-2:2001. At no time will the steady-state voltage regulation exceed 2%.

DE RATES

All values tabulated on page 8 are subject to the following reductions

5% when air inlet filters are fitted.

3% for every 500 metres by which the operating altitude exceeds 1000 metres above mean sea level.

3% for every 5°C by which the operational ambient temperature exceeds 50°C.

Note: Requirement for operating in an ambient exceeding 60°C must be referred to the factory.

5% For reverse rotation

(Standard rotation CW when viewed from DE)

NB Continuous development of our products entitles us to change specification details without notice, therefore they must not be regarded as binding.

Front cover drawing typical of product range.



PM042E

WINDING 311 Single Phase AS480 AVR WITH EXCITATION BOOST SYSTEM (EBS)

CONTROL SYSTEM


CONTROL STSTEM	A0400 AVIT WITH EXCITATION BOOOT OTOTEM (EBO)								
VOLTAGE REGULATION	± 1.0 %								
SUSTAINED SHORT CIRCUIT	REFER TO SHO	REFER TO SHORT CIRCUIT DECREMENT CURVE (page 7)							
INSULATION SYSTEM		CLASS H							
PROTECTION			IP	23					
RATED POWER FACTOR			0	.8					
STATOR WINDING			DOUBLE LAYER	R CONCENTRIC					
WINDING PITCH			TWO	HIRDS					
WINDING LEADS			1	2					
STATOR WDG. RESISTANCE		0.563 Ohn	ns AT 22°C DOU	JBLE DELTA CO	NNECTED				
ROTOR WDG. RESISTANCE			0.895 Ohn	ns at 22°C					
EXCITER STATOR RESISTANCE			13.5 Ohm	s at 22°C					
EXCITER ROTOR RESISTANCE		0	.0479 Ohms PE	R PHASE AT 22°	С				
EBS STATOR RESISTANCE			12.9 Ohm	s at 22°C					
R.F.I. SUPPRESSION	BS EN 610	00-6-2 & BS EN	61000-6-4,VDE (0875G, VDE 0875	5N. refer to factor	ry for others			
WAVEFORM DISTORTION		NO LOAD 1	.5% NON-DISTO	ORTING LINEAR	LOAD < 5.0%				
MAXIMUM OVERSPEED		70	4500 F	Rev/Min					
BEARING DRIVE END		70	BALL. 6309	9-2RS (ISO)					
BEARING NON-DRIVE END			BALL. 6306	6-2RS (ISO)					
		1 BEARING			2 BEARING				
WEIGHT COMP. GENERATOR		84 kg			87 kg				
WEIGHT WOUND STATOR		36.3 kg			36.3 kg				
WEIGHT WOUND ROTOR		25.89 kg			26.95 kg				
WR² INERTIA		0.0686 kgm ²			0.0688 kgm ²				
SHIPPING WEIGHTS in a crate		100 kg			109 kg				
PACKING CRATE SIZE		71 x 51 x 67 (cm))		71 x 51 x 67 (cm)			
		50 Hz			60 Hz				
TELEPHONE INTERFERENCE		THF<2%			TIF<50				
COOLING AIR	0.2	:05 m³/sec 434 c	efm	0.241 m³/sec 511 cfm					
VOLTAGE DOUBLE DELTA	220 / 110	230 / 115	240 / 120	220 / 110	230 / 115	240 / 120			
VOLTAGE PARALLEL DELTA	110	115	120	110	115	120			
kVA BASE RATING FOR REACTANCE VALUES	8.0	8.0	8.0	8.0	8.4	8.7			
Xd DIR. AXIS SYNCHRONOUS	1.60	1.46	1.34	2.11	2.02	1.92			
X'd DIR. AXIS TRANSIENT	0.17	0.15	0.14	0.21	0.20	0.19			
X"d DIR. AXIS SUBTRANSIENT	0.11	0.10	0.09	0.13	0.13	0.12			
Xq QUAD. AXIS REACTANCE	0.79	0.73	0.67	1.05	1.01	0.96			
X"q QUAD. AXIS SUBTRANSIENT	0.18	0.16	0.15	0.24	0.23	0.22			
XL LEAKAGE REACTANCE	0.07	0.07	0.06	0.10	0.09	0.09			
X2 NEGATIVE SEQUENCE	0.15	0.14	0.12	0.19	0.18	0.18			
X ₀ ZERO SEQUENCE	0.07 0.07 0.06 0.10 0.09 0.09					0.09			
	REA	ACTANCES ARE	SATURATED						
T'd TRANSIENT TIME CONST.			0.0	08 s					
T"d SUB-TRANSTIME CONST.			0.0	02 s					
T'do O.C. FIELD TIME CONST.			0.1	5 s					
Ta ARMATURE TIME CONST.			0.0	04 s					
SHORT CIRCUIT RATIO			1/	Xd					


50 Hz


PMO42E Winding 311 Single Phase

STAMFORD

SINGLE PHASE EFFICIENCY CURVES









60 Hz


PMO42E Winding 311 Single Phase

STAMFORD

SINGLE PHASE EFFICIENCY CURVES











PM042E

Winding 311 Single Phase AS480 AVR With EBS fitted Locked Rotor Motor Starting Curves






PM042E

STAMFORD

Winding 311 Single Phase

WITH EBS FITTED

Single-phase Short Circuit Decrement Curve. No-load Excitation at Rated Speed Based on Double Delta connection.



Sustained Short Circuit = 164 Amps

Note

The following multiplication factors should be used to adjust the values from curve between time 0.001 seconds and the minimum current point in respect of nominal operating voltage:

Voltage	Factor
220V	X 1.00
230V	X 1.05
240V	X 1.09

The sustained current value is constant irrespective of voltage level

PMO42E Winding 311 Single Phase

RATINGS

50Hz

Class - Temp Rise	Cont	Cont. E - 65/50°C		Cont. B - 70/50°C		Cont. F - 90/50°C			Cont. H - 110/50°C			
Ciass - Temp Rise		0.8pf			0.8pf		0.8pf			0.8pf		
Double Delta (V)	220	230	240	220	230	240	220	230	240	220	230	240
Parallel Delta (V)	110	115	120	110	115	120	110	115	120	110	115	120
kVA	6.1	6.1	6.1	6.3	6.3	6.3	7.2	7.2	7.2	8.0	8.0	8.0
kW	4.9	4.9	4.9	5.0	5.0	5.0	5.8	5.8	5.8	6.4	6.4	6.4
Efficiency (%)	66.6	66.5	66.4	66.9	66.8	66.7	67.7	67.8	67.8	68.2	68.3	68.4
kW Input	7.4	7.4	7.4	7.5	7.5	7.5	8.6	8.6	8.6	9.4	9.4	9.4

Class - Temp Rise	Cont	Cont. E - 65/50°C		Cont. B - 70/	Cont. F - 90/50°C			Cont. H - 110/50°C			
Class - Temp Rise		1.0pf		◯ 1.0pf			1.0pf			1.0pf	
Double Delta (V)	220	230	240	220 230	240	220	230	240	220	230	240
Parallel Delta (V)	110	115	120	110 115	120	110	115	120	110	115	120
kVA	6.1	6.1	6.1	6.3 6.3	6.3	7.2	7.2	7.2	8.0	8.0	8.0
kW	6.1	6.1	6.1	6.3 6.3	6.3	7.2	7.2	7.2	8.0	8.0	8.0
Efficiency (%)	72.2	72.1	72.0	72.4 72.4	72.3	73.2	73.3	73.3	73.6	73.8	73.9
kW Input	8.4	8.5	8.5	8.7	8.7	9.8	9.8	9.8	10.9	10.8	10.8


60Hz

Class Town Disc	Cont	. E - 65	/50°C	Cont	<mark>B</mark> - 70	/50°C	Cont.	F - 90	/50°C	Cont.	H - 110)/50°C
Class - Temp Rise		0.8pf		(0.8pf			0.8pf			0.8pf	
Double Delta (V)	220	230	240	220<	230	240	220	230	240	220	230	240
Parallel Delta (V)	110	115	120	110	115	120	110	115	120	110	115	120
kVA	6.1	6.5	6.7	6.3	6.7	7.0	7.2	7.6	7.9	8.0	8.4	8.7
kW	4.9	5.2	5.4	5.0	5.4	5.6	5.8	6.1	6.3	6.4	6.7	7.0
Efficiency (%)	62.2	63.0	63.4	62.6	63.4	63.9	63.9	64.6	65.0	64.7	65.3	65.8
kW Input	7.9	8.3	8.5	8.0	8.5	8.8	9.1	9.4	9.7	9.9	10.3	10.6

Class - Temp Rise	Cont	Cont. E - 65/50°C		ont. E - 65/50°C Cont. B - 70/50°C		Cont. F - 90/50°C			Cont. H - 110/50°C			
Class - Temp Rise		1.0pf			1.0pf			1.0pf			1.0pf	
Double Delta (V)	220	230	240	220	230	240	220	230	240	220	230	240
Parallel Delta (V)	110	115	120	110	115	120	110	115	120	110	115	120
kVA	6.1	6.5	6.7	6.3	6.7	7.0	7.2	7.6	7.9	8.0	8.4	8.7
kW	6.1	6.5	6.7	6.3	6.7	7.0	7.2	7.6	7.9	8.0	8.4	8.7
Efficiency (%)	67.9	68.6	69.0	68.2	68.9	69.4	69.4	70.0	70.5	70.1	70.7	71.2
kW Input	9.0	9.5	9.7	9.2	9.7	10.1	10.4	10.9	11.2	11.4	11.9	12.2

PMO42E Winding 311 Single Phase

DIMENSIONS



COUPLI	NG DISC
SAE	"AN"
6.5	30.2
7.5	30.2
8	62
10	53.8
11.5	39.6

I-BRG A	DAPTORS
SAE	D.
5	361
4	405
3	451
2	489

8-HOLES	SPACED	AS	12
8-HOLES	SPACED	AS	12

2-BRG ADAPTORS					
SAE	Ø "E"				
5	359				
4	406				
3	455				
2	493				



APPROVED DOCUMENT

STAMFORD

Head Office Address: Barnack Road, Stamford Lincolnshire, PE9 2NB United Kingdom

Tel: +44 (0) 1780 484000 Fax: +44 (0) 1780 484100

www.cumminsgeneratortechnologies.com

Copyright 2010, Cummins Generator Technologies Ltd, All Rights Reserved Stamford and AvK are registered trade marks of Cummins Generator Technologies Ltd Cummins and the Cummins logo are registered trade marks of Cummins Inc.